

Certificate of Compliance

Certificate: 1460995 (LR 113111)

Master Contract: 174517

Project: 1460995

Date Issued: August 20, 2003

Issued to: ASCO Controls BV
Industrielaan 21
3925 BD Scherpenzeel
THE NETHERLANDS

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US'



Authorized by: G. Foulem

PRODUCTS

Class 3221 01 VALVES

Class 3221 81 VALVES, Certified to US Standard

- Solenoid Valve Coils, Class F insulation system 50/60 Hz, 6.3 W: series 145062-0xx, 50/60 Hz, 12 W, 24-230 V; series 400425-1yyZ, 11.2 W, 6-240 Vdc.

Notes:

1. The letters "xx" in the type designations of series 145062-0xx will be completed by numbers 01 to 18 to indicate rating details.
2. The letters "yy" in the type designations of series 400425-1yyZ will be completed by numbers 40 to 54 to indicate rating details.
3. These devices are Certified only as a component part for use on valve bodies, where the suitability of the combination (including combination coil/valve) is to be determined by CSA International.

The 'C' and 'US' indicators adjacent to the CSA Mark signify that the product has been evaluated to the applicable CSA and ANSI/UL Standards, for use in Canada and the U.S., respectively. This 'US' indicator includes products eligible to bear the 'NRTL' indicator. NRTL, i.e. National Recognized Testing Laboratory, is a designation granted by the U.S. Occupational Safety and Health Administration (OSHA) to laboratories which have been recognized to perform certification to U.S. Standards.

Certificate: 1460995

Master Contract: 174517

Project: 1460995

Date: August 20, 2003

APPLICABLE REQUIREMENTS

CSA Standard C22.2 No. 0-M91

General Requirements

CSA Standard C22.2 No. 139-1982

Electrically Operated Valves

UL Standard No. 429, 5th edition

Electrically Operated Valves